

Chief Safety Officer Decision (Regulatory Equivalence)

Date:

22 April 2016

C-NLOPB Reference:

2016-RQ-0088

Applicant:

Transocean Canada Drilling Services Ltd.

Applicant Reference:

RQF-HGR-250

Installation Name:

MODU Henry Goodrich

Authority:

*Canada-Newfoundland Atlantic Accord Implementation Act,
subsection 151(1) & section 205.069*

*Canada-Newfoundland and Labrador Atlantic Accord
Implementation Newfoundland and Labrador Act, subsection
146(1) and section 201.66*

Regulation:

*Subsection 29(5) of the Newfoundland Offshore Petroleum
Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the owner of the *MODU Henry Goodrich*, to carry a minimum supply of replacement extinguishers as identified in the Application in lieu of a spare charge for each pe of extinguisher onboard, provided used extinguishers are replaced without delay.



Chief Safety Officer