

Chief Safety Officer Decision (Regulatory Substitution)

Date: 22 JUNE 2016

C-NLOPB Reference: 2016-RQ-0115

Applicant: Technip Canada Limited

Applicant Reference: 066467C001-RQF-32

Installation Name: M/V North Sea Giant

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) and section 201.66

Regulation: *Subsection 30(1) of the Canada–Newfoundland and Labrador Petroleum Installation Regulations*

Decision:

The Chief Safety Officer accepts the Applicant's, the owner of the *M/V North Sea Giant*, use of 6 sets of firefighter equipment that meet the requirements of *"DNV.GL Rules & Guidelines 1-Ship technology, Part 4, Chapter 10 – Fire Safety"*, *"International Maritime Organization Safety of Life at Sea Reg II-2, Part C, Regulation 10"* & *"Fire Safety Systems (FSS) Code, Chapter 3"* in lieu of the *"Canada–Newfoundland and Labrador Petroleum Installation Regulations"* requirement which specifies the Operator must ensure that a workplace that is a manned installation be provided with at least 10 sets of firefighter equipment that meet the requirements of *"National Fire Protection Association (NFPA) Standard on Protective Clothing for Structural Fire Fighting"*, *"NFPA Standard on Gloves for Structural Fire Fighting"*; and *"CAN/CSA-Z94.1-05, Industrial Protective Headwear for Performance, Selection, Care and Use"*.


Chief Safety Officer