



**Chief Safety Officer Decision**  
**(Application for Substitution, Equivalency, or Exemption)**

**Date:** 2022-Feb-07 | 8:32:11 AM NST

**C-NLOPB Reference:** 2020-RQ-0088

**Applicant:** Hibernia Management Development Company

**Applicant Reference:** RQF 479

**Installation Name:** Hibernia Platform

**Authority:** *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*  
  
*Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) & section 201.66*

**Regulation:** *Subsection 29(5) of the Newfoundland Offshore Petroleum Installations Regulations*

**Decision:**

The Chief Safety Officer approves the Applicant's, the owner of the *Hibernia Platform*, proposal to have a ten percent supply of replacement portable extinguishers on the installation of each size and type to replace discharged or partially discharged extinguishers, in lieu of the requirements in Subsection **29(5)** of the *Newfoundland Offshore Petroleum Installations Regulations*, which states "A spare charge shall be provided for each portable extinguisher provided pursuant to this section for which a duplicate extinguisher has not been provided."

This Decision is effective from the date of issuance herein until the earlier of:

- a) the date a Regulation referenced herein is repealed or the date a particular subsection that is the object of a substitution or exemption being granted hereby is amended or replaced, or
- b) the date on which the CSO and /or CCO (as applicable) revokes this Decision as a result of i) any enforcement action by the Board related to this Decision or ii) new information or analysis coming to light challenging the assessment upon which this Decision was based, including but not limited to any changes to commitments made by the Applicant in its application.

DocuSigned by:  
  
94C2434A59B546B  
Chief Safety Officer