



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: 2022-Jun-29 | 12:01:44 PM NDT

C-NLOPB Reference: 2022-RQ-0025

Applicant: Stena Drilling Ltd

Applicant Reference: SFO-RQ-020-044 Rev 2

Installation Name: MV Stena Forth

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) and section 201.66

Regulation: *Subsection 8(8) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer approves the Applicant's, the owner of the *MV Stena Forth*, use of electrical equipment installed in hazardous areas on the *Stena Forth*, which is selected, certified, installed and maintained in compliance with *DNV offshore standard DNV-OS-D201: Section 11 Hazardous Areas Installations*, in lieu of the requirements in Subsection 8(8) of the *Newfoundland Offshore Petroleum Installations Regulations*, which requires, all electrical equipment in hazardous locations to meet Part I of the *Canadian Electrical Code* and the *Oil and Gas Occupational Health and Safety Regulations*.

DocuSigned by:

A674D4E3A098456...
Chief Safety Officer