



**Chief Safety Officer(Regulatory Equivalence)**

**Date:** June 1, 2011

**C-NLOPB Reference:** 2010-RQ-0008

**Applicant:** Husky Oil Operations Ltd.

**Applicant Reference:** RQF WR 147A

**Installation Name:** *Newfoundland Offshore Petroleum Installations Regulations, Paragraph 27(1)(A)*

**Authority:** *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

**Regulation:** *Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)*

**Decision:**

The Chief Safety Officer authorizes the applicant, the operator for the White Rose Project, to car-seal the accommodations sprinkler valves open and to conduct an inspection of those valves at least once every three months instead of monitoring the status of these valves in the central control room.

  
\_\_\_\_\_  
Chief Safety Officer