



**Chief Safety Officer Decision (Regulatory Equivalence)**

**Date:** February 11, 2013

**C-NLOPB Reference:** 2012-RQ-0118

**Applicant:** ExxonMobil Canada Ltd., as managing partner of  
ExxonMobil Canada Properties

**Applicant Reference:** HEB-022

**Installation Name:** Hebron

**Authority:** *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*  
  
*Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)*

**Regulation:** *subsections 27(1), (2), (3), (4), (5), (10), (11) of the Newfoundland Offshore Petroleum Installations Regulations*

**Decision:**

The Chief Safety Officer authorizes the Applicant, the operator of the Hebron Installation, to carry a minimum 10% supply of replacement portable extinguishers in lieu of a spare charge for each type of extinguisher onboard provided used extinguishers are replaced without delay.

  
\_\_\_\_\_  
Chief Safety Officer