



Chief Safety Officer Decision (Regulatory Equivalence)

Date: February 11, 2013

C-NLOPB Reference: 2012-RQ-0123

Applicant: Seadrill Canada Limited

Applicant Reference: WA-IR-014

Installation Name: West Aquarius

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsections 29(4) & 29(9) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision: The Chief Safety Officer authorizes the Applicant, the owner of the West Aquarius, to use the *International Maritime Organization (IMO) Mobile Offshore Drilling Unit (MODU) Code 1989* and the *Safety of Life at Sea (SOLAS)* regulations for portable fire extinguishers in lieu of the referenced regulatory requirements provided the inspection, maintenance and recharging of fire extinguishers are carried out to *National Fire Protection Association (NFPA) 10* requirements.


Chief Safety Officer