



Chief Safety Officer Decision (Regulatory Equivalence)

Date: February 15, 2013

C-NLOPB Reference: 2012-RQ-0149

Applicant: Seadrill Canada Limited

Applicant Reference: WA-IR-OSH-003 Item 2

Installation Name: West Aquarius

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsections 8(8), 11(1) and subparagraph 11(2b) of the Newfoundland Offshore Petroleum Installations Regulations and section 8.14 of the Petroleum OSH Regulations*

Decision:

The Chief Safety Officer accepts the Applicant's use of Det Norske Veritas' (DNV) Offshore Standards, DNV-OS-D201, Electrical Installation, April 2011 including the International Electrotechnical Commission (IEC) Publication 92 for Electrical Installations on Ships for the design and installation of the electrical systems for the West Aquarius provided any new cabling is installed in accordance with the *Installation Regulations*.



Chief Safety Officer