



Chief Safety Officer Decision (Regulatory Equivalence)

Date: February 18th, 2013

C-NLOPB Reference: 2013-RQ-0004

Applicant: Seadrill Canada Limited

Applicant Reference: WA-IR-025

Installation Name: West Aquarius

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsection 27(11) of the Newfoundland Offshore Installations Regulations*

Decision:

The Chief Safety Officer accepts that the accommodation sprinkler system on the West Aquarius was installed in accordance with International Maritime Organization (IMO) Fire Safety Systems (FSS) Code Chapter 8 in lieu of the *National Fire Protection Association (NFPA) 13 Standard for the Installation of Sprinkler Systems* and the inspection, testing and maintenance will meet NFPA requirements.


Chief Safety Officer