



**Chief Safety Officer (Regulatory Equivalence)**

**Date:** July 10, 2014

**C-NLOPB Reference:** 2014-RQ-0058

**Applicant:** Suncor Energy Inc.

**Applicant Reference:** RQF 267

**Installation Name:** Terra Nova FPSO


**Authority:** *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

**Regulation:** *Newfoundland Offshore Petroleum Installations Regulations, Paragraph 8(2)*

**Decision:**

The Chief Safety Officer concurs with the Applicant's proposal to conduct hot work to repair the aft door of the hydraulic power pack room whilst in production provided all risk reduction measures outlined in the Application are followed. The Application has been approved subject to the following conditions:

1. The safety systems (i.e. positive pressure control and DCS alarms to the control room in the event of loss of pressure, fire and gas detection within the space and the air intakes to the space, fire suppression) protecting this area are operational.
2. On loss of positive pressure within the enclosure all welding is to cease and any non-hazardous area equipment (i.e. welding machines) are electrically isolated.

  
\_\_\_\_\_  
Chief Safety Officer