



**Chief Safety Officer Decision (Regulatory Equivalence)**

**Date:** July 22, 2013

**C-NLOPB Reference:** 2013-RQ-0007

**Applicant:** ExxonMobil Canada Ltd., as managing partner of  
ExxonMobil Canada Properties

**Applicant Reference:** HEB-032

**Installation Name:** Hebron Installation

**Authority:** *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*  
  
*Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)*

**Regulation:** *Subsections 24(1) and 24(3) of the Newfoundland Offshore Petroleum Installations Regulations*

**Decision:**

The Chief Safety Officer accepts the use of portable fire suppression equipment at elevated heights within the Derrick of the Hebron Installation in lieu of a fixed fire protection system, as outlined in the application.

  
Chief Safety Officer