



**Chief Safety Officer Decision (Regulatory Equivalence)**

**Date:** July 23, 2013

**C-NLOPB Reference:** 2012-RQ-0127

**Applicant:** ExxonMobil Canada Ltd., as managing partner of  
ExxonMobil Canada Properties

**Applicant Reference:** RQF-HEB-050

**Installation Name:** Hebron Installation

**Authority:** *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*  
  
*Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)*

**Regulation:** *Section 24 of the Newfoundland Offshore Petroleum Installations Regulations*

**Decision:**

The Chief Safety Officer accepts the use of fire hose reels within the Drilling Equipment Set (DES) module of the Hebron Installation that will meet the requirements of the "National Fire Protection Association, NFPA 14 Standard for the Installation of Standpipe and Hose systems" in lieu of fire hydrants.

  
Chief Safety Officer