



Chief Safety Officer Decision (Regulatory Exemption)

Date: June 18, 2012

C-NLOPB Reference: 2012-RQ-0037

Applicant: Subsea 7 Canada Inc.

Applicant Reference: TRNCA-RQF-HAV-00002 – Item 05

Installation Name: Seven Havila

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Section 27 of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer exempts the Applicant, the owner of the Seven Havila, from installing a sprinkler system in the accommodations area on the Seven Havila. The Seven Havila is in compliance with International Maritime Organization Safety of Life at Sea requirements and is fitted with fire rated panels, decks, ceilings with fire rated insulation and doors for inhibiting escalation of fire from one area to another. The vessel is fitted with a fire detection and alarm system.



Chief Safety Officer