



Chief Safety Officer Decision (Regulatory Equivalence)

Date: June 7 2012

C-NLOPB Reference: 2012-RQ-0003

Applicant: Suncor Energy Inc.

Applicant Reference: RQF TNA 159 Rev 1

Installation Name: Terra Nova FPSO

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Sections 29(5) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:
The Chief Safety Officer authorizes the Applicant, the operator for the Terra Nova FPSO, to carry a supply of replacement portable extinguishers in lieu of a spare charge for each extinguisher onboard as outlined in their proposal.


Chief Safety Officer