



Chief Safety Officer Decision (Regulatory Equivalence)

Date: March 8, 2012

C-NLOPB Reference: 2011-RQ-0020

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-008

Installation Name: Hebron Project

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Sections 11(2) of the Newfoundland Offshore Petroleum Installations Regulations (IEC 92-3 & IEC 332-3)*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator for the Hebron project, to use the most recent "International Electrotechnical Commission" (IEC) Standards as outlined in the Applicant's proposal for the design of electrical wiring for the Hebron installation. In lieu of IEC 92-3, the use of IEC 60092-350, IEC 60092-351, IEC 60092-353, IEC 60092-353 AMD, IEC 60092-354, IEC 60092-376 and IEEE 1580-2001 and in lieu of IEC 332-3, the use of IEC 60332-3-22.

A/ Chief Safety Officer