



Chief Safety Officer Decision (Regulatory Equivalence)

Date: March 9, 2012

C-NLOPB Reference: 2011-RQ-0021

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-004

Installation Name: Hebron Project

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Sections 2(2) and 11(1) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator for the Hebron project, to use API RP 505 and API RP 14FZ as outlined in the Applicant's proposal for hazardous area classification and the design and installation of electrical systems for the Hebron installation in lieu of API RP 500 and API RP 14F as referenced in the regulations.

A / 
Chief Safety Officer