



Chief Safety Officer Decision (Regulatory Equivalence)

Date: 15 October 2014

C-NLOPB Reference: 2014-RQ-0096

Applicant: Seadrill Canada Limited

Applicant Reference: WH-IR-OSH-003 Item 2

Installation Name: West Hercules

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*
Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsections 8(8), 11(1) and paragraph 11(2)(b) of the Newfoundland Offshore Petroleum Installations Regulations and sections 8.12 and 8.14 of the Petroleum OSH Regulations*

Decision:

The Chief Safety Officer accepts the Applicant's use of Det Norske Veritas' Offshore Service Specification *DNV-OSS-201 – Verification for Compliance with Norwegian Shelf Regulations* (July 2003), DNV Offshore Standards, *DNV-OS-A101 – Safety Principles and Arrangements* (October 2002) and *DNV-OS-D201 Electrical Installation* (April 2011) including the *International Electrotechnical Commission (IEC) Publication 92 for Electrical Installations on Ships* for the design and installation of the electrical systems for the West Hercules provided any new cabling is installed in accordance with *Installation Regulations 11(2)(b)*.



Chief Safety Officer