



Chief Safety Officer Decision (Regulatory Equivalence)

Date: September 4, 2013

C-NLOPB Reference: 2012-RQ-0119

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-037

Installation Name: Hebron Installation

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Subsections 25(2), 25(6) and 28(1)(d) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the Hebron Installation, to use fire hose reels and hydrants in the mud tank room of the Drilling Support Module (DSM) in lieu of a fixed fire protection system provided the drilling fluid types used are limited to Class III B, combustible liquids as per *American Petroleum Institute (API) Recommended Practice 505*.


Chief Safety Officer