



Chief Safety Officer Decision (Regulatory Equivalence)

Date: September 17, 2012

C-NLOPB Reference: 2012-RQ-0024

Applicant: ExxonMobil Canada Ltd., as managing partner of
ExxonMobil Canada Properties

Applicant Reference: RQF-HEB-019

Installation Name: Hebron Project

Authority: *Canada-Newfoundland Atlantic Accord Implementation Act, subsection 151(1)*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1)

Regulation: *Section 11(1) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer authorizes the Applicant, the operator of the Hebron Project, to use the Canadian Electrical Code (CEC) C22.1, Part 1 for the design, installation and maintenance of electrical equipment.


Chief Safety Officer